



NOTES

1. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH PROJECT SPECIFICATIONS & ALL OTHER CONTRACT DOCUMENTATION & DRAWINGS AS ISSUED BY THE ARCHITECT, STRUCTURAL ENGINEERS & CONSULTING ENGINEERS.

2. ALL DIMENSIONS IN MILLIMETRES UNLESS OTHERWISE STATED.

3. THE CONTRACTOR SHALL NOTE THAT THIS DRAWING IS INDICATIVE AND ILLUSTRATES DESIGN INTENT ONLY. THE CONTRACTOR SHALL BE RESPONSIBLE FOR THE DETAILED DESIGN AND COORDINATION WITH THE STRUCTURE AND OTHER SERVICES.

4. ANY DISCREPANCIES, ERRORS OR OMISSIONS ARE TO BE CLARIFIED WITH THE RELEVANT ENGINEER AT THE EARLIEST OPPORTUNITY.

5. ALL WORKS TO BE IN ACCORDANCE WITH THE CURRENT RELEVANT REGULATIONS PRACTICE & TRADE ASSOCIATION REQUIREMENTS.

6. THE ELECTRICAL CONTRACTOR SHALL PROVIDE ALL NECESSARY SUPPORTS AND MOUNTING ACCESSORIES.

7. ALL ELECTRICAL INSTALLATIONS SHALL COMPLY WITH THE CURRENT I.S. 10101 WIRING REGULATIONS.

LEGEND

PUBLIC LIGHTING

LUMINAIRE A: (GUZZINI UFO RESIDENTIAL OPTIC - 3.64 KLM - 6M COLUMN - 3000K - DIMMED TO 50%)

LUMINAIRE B: (GUZZINI TWILIGHT COPENHAGEN - SYMMETRIC OPTIC - 3.4 KLM - 6M COLUMN - 3000K - DIMMED TO 50%)

LUMINAIRE C: (GUZZINI TWILIGHT COPENHAGEN - ASYMMETRIC OPTIC - 5.47 KLM - 6M COLUMN - 3000K - DIMMED TO 33%)

Carpark Entrance

Results - Horizontal Illuminance (lux)

E_{avg}= 8.79

E_{min}= 1.83

E_{max}= 12.92

E_{min}/E_{avg}= 0.14

E_{min}/E_{avg}= 0.21

E_{max}/E_{avg}= 1.47

General Work Area

Results - Horizontal Illuminance (lux)

E_{avg}= 6.11

E_{min}= 1.23

E_{max}= 13.18

E_{min}/E_{avg}= 0.09

E_{min}/E_{avg}= 0.20

E_{max}/E_{avg}= 2.16

P03

05.03.25

ISSUED FOR INFORMATION

MOC

MOS

P02

26.02.25

ISSUED FOR INFORMATION

MOC

MOS

P01

12.02.25

ISSUED FOR INFORMATION

RU

MOS

Rev

Date

Description

RU

App

Client

DUFFY PROPERTY GROUP

Project

KINSALE LIGHTING DESIGN

Title

PUBLIC LIGHTING LAYOUT

Drawing No

C25001-EDC-XX-00-DR-E-3000

RIBA Work Stage

STAGE 3

Status Code

S3

Revision

P03

Scale @ A1

1:200

Model Manager

MOS

Project Manager

MOS

EDC

Mechanical & Electrical Consulting Engineers

Call Office

+353 (0)1 4265476

email: info@edcengineers.com

Design Office

+353 (0)1 5313453

email: info@edcengineers.com

London Office

+44 (0)20 74940000

email: info@edcengineers.com

www.edcengineers.com

THIS DRAWING IS THE PROPERTY OF EDC ENGINEERS. IT IS TO BE USED ONLY FOR THE PROJECT AND SITE SPECIFICALLY IDENTIFIED. IT IS NOT TO BE REPRODUCED OR COPIED IN ANY FORM OR BY ANY MEANS, WITHOUT THE WRITTEN PERMISSION OF EDC ENGINEERS.

ISO 9001

BIM